

Message

From: Jim Robertson [jrobertson@desertviewpower.com]
Sent: 7/24/2020 10:18:51 PM
To: AEO_R9 [AEO_R9@epa.gov]
CC: TLiebel@aqmd.gov; Kdudash@aqmd.gov; Greg Cook [gcook@greenleaf-power.com]; Mitchell Martin [mmartin@greenleaf-power.com]; Jennifer Gavaldon [jgavaldon@greenleaf-power.com]
Subject: 48 hr. Notification of HCl exceedance - Desert View Power Permit No. CB-OP 99-01
Attachments: ATT00001.txt

Per the requirements of PSD permit SE 87-01 condition III.C.2 and 40 CFR § 71.6 (a)(3)(iii), this email serves as Desert View Power's (DVP) 48 hr. notification for an excess of HCl. On July 24, 2020, DVP received the final Boiler MACT compliance test results that occurred on June 2-3, 2020. The HCl emission result for Unit 1 was 0.0248 lb/MMBtu, and 0.0481 lb/MMBtu for Unit 2, both above the 0.022lb/MMBtu emissions limit. Below, you will find a link to access the final Boiler MACT test results. This link will expire on July 30, 2020. As required, a certified written notification will be submitted within 10 working day of this email.

Ex. 6 Personal Privacy (PP)

If you have any questions, please do not hesitate to contact me.

Sincerely,

Jim Robertson
Plant Manager
62-300 Gene Welmas Drive
Mecca, CA 92254-0758
Office: 760-262-1682
jrobertson@desertviewpower.com
www.greenleaf-power.com